



Terminal Box
*Type A11-**-******

Exepd GmbH
i_PARK TAUBERFRANKEN 23
97922 Lauda-Königshofen
Germany
Phone: ++49 (0) 9343 627055-0
Fax: ++49 (0) 9343 627055-99
Mail: info@exepd.de



- 1. Product Description 3**
- 2. Normal Handling 3**
- 3. Used Standards..... 3**
- 4. Technical Data 4**
- 5. Electrical Data..... 4**
- 6. Components / Cable Glands..... 4**
- 7. Safety references..... 5**
- 8. Installation 5**
- 9. Starting..... 6**
- 10. Use, Maintenance and Elimination of Disturbances 6**
- 11. Accessories and spare parts 6**
- 12. Service adress 6**

1. Product Description

The Terminal Box Type A11-**-***** is built with an enclosure made of polyester, aluminium, sheet steel or stainless steel.

For **category 2G** control and terminal boxes, the boxes are assembled with certified cable glands, terminals in the types of protection Ex e and also for intrinsically safe circuits Ex i.

For **category 2D** control and terminal boxes, the boxes are assembled with IP 6x approved cable glands. Inside the box, on demand, it is fitted with terminals.

The construction and functionality of the control and terminal boxes for the use in the marked Ex zones is tested and documented by Exepd GmbH piece by piece. The passed quality test is shown by marking the box with the Ex type label.

2. Normal Handling

The Terminal Box Type A11-**-***** is built for local installation in Ex zone 1 and zone 21. It is not allowed to install the product in zone 0 or zone 20.

Inside the control and terminal box there are explosion protected electrical and mechanical equipment and their accessories installed.

The individual Type label shows all the electrical and for the installation in hazardous area required data.

If there is no information about the ambient temperature on the type label, the boxes can be used in the temperature range of -20°C up to 40°C.

It is prohibited to make any changes on the Terminal Boxes without contacting the manufacturer.

3. Used Standards

(Depending on the assembled components)

DIN EN 60079-0:2004 / General requirements
DIN EN 60079-7:2003 / Increased safety „e“
pr DIN IEC 60079-11:2004 / Intrinsically safety „i“
pr DIN EN 61241-0:2002 / General requirements
pr DIN EN 61241-0/AA:2005 /General requirement
DIN EN 61241-1:2004 /Protection by enclosure „tD“

4. Technical Data

Enclosure material

Type A21-*1-*****	Polyester black
Type A21-*2-*****	Aluminium AlSi 12
Type A21-*3-*****	Stainless steel 1.4301 (V2A)
Type A21-*4-*****	Stainless steel 1.4404 (V4A)
Type A21-*5-*****	Painted sheet steel

Mechanical strength according to DIN EN 60079-0:2004: 7 Nm

Protection according to 60529/IEC 60529: IP 54 up to IP 65

Ambient temperature range:

Temperature class T4	max. -50°C up to + 60°C
Temperature class T6 or T 80°C	max. -50°C up to + 60°C

Explosion protection:
(please refer to type label for details)

- ⊕ II 2D Ex tD A21 IP 6X T 80°C
- ⊕ II 2(1)G Ex e ia/ib [ia/ib] IIA, IIB, IIC T4/ T6

EC type examination certificate: TPS 08 ATEX 61951 4

5. Electrical Data

(please refer to type label)


Maximum rated voltage:	1100 V
Maximum rated current:	500 A
Maximum cross section:	300 mm ²
Maximum power loss:	500W

6. Components / Cable Glands

With the Control and Terminal Box only separate certified components like terminals, switches and control and signal units are used. Not used holes for cable glands or operators have to be closed by certified plugs.
Assembly and safety instruction of the component manufacturer must be considered.

7. Safety references

Devices in hazardous area must be installed, supervised, maintained and kept in good conditions by the owner of the plant. Part of this is an inspection after the transport to identify possible damages caused during the transport.
Only qualified workers are allowed to install and dismount as well as doing maintenance work on the control and terminal boxes. All universally valid rules and laws and other binding directives for the safety of people and environment must be kept.

 WARNING	<p style="text-align: center;">DO NOT OPEN WHILE ENERGIZED!! DUST LAYERS >5 mm MUST BE REMOVED! DO NOT USE DEFECT EQUIPMENT!</p>
--	--

8. Installation

Mounting

The control and terminal boxes must be protected against aggressive and unusual environmental conditions which could cause damages on the equipment. This could be e.g. acids or high and low temperatures.

For installation, please refer to IEC / EN 60079-14 and other valid standards and directivities on the place of erection.

Information on the type label must be kept!

If cable glands marked with and „X“ are in use, please refer to the operation manual of the gland supplier.

Installation

The wire connection must be made in such a manner, that the insulation material and the cores itself will not be damaged. Regarding the maximum possible cross connection and electrical data, please refer to the information written on the type label.

Metal enclosures, installed in hazardous area, must be connected to the general earth system via a cable with minimum 4 mm² cross section.

If intrinsically safe circuit installed in one box together with increased safe or energy limited circuits, the installation must protect the Ex i circuit from an increase of capacity, voltage and inductivity.

The air and creeping distance between Ex e and Ex i circuits must be kept by the internal installation.

9. Starting

Before the Terminal Box is put into operation, the qualification for the use in the predominant hazardous area must be proofed according to the type label and the zone declaration.

It is not allowed to exceed the written data on the type label.

By using the equipment in hazardous area with combustible dust, dust layers > 5 mm must be removed. To protect the equipment from these circumstances also the installation of protection hoods are possible.

The functionality of terminal box itself, as well as its combination with the plant or machine must be tested before the first use.

Only use the Control and Terminal Box in clean and intact condition.

10. Operation, Maintenance and Elimination of Disturbances

Devices in hazardous area must be installed, supervised, maintained and kept in good conditions by the owner of the plant. For information, refer to IEC / EN 60079-17. Only skilled workers are allowed to do maintenance and the elimination of disturbance work. Before doing this work, the safety requirements must be kept!

For elimination of disturbances, only original spare parts after consulting with Exepd are allowed to use. Before using them again, the safety requirements must be kept!

11. Accessories and spare parts

Please refer to www.exepd.de

12. Service adress

Exepd GmbH
i_PARK TAUBERFRANKEN 23
97922 Lauda-Königshofen
Germany
Phone: ++49 (0) 9343 627055-0
Fax: ++49 (0) 9343 627055-99
Mail: info@exepd.de
www.exepd.de